

G3-PLCCERTIFIED
CEN A

C E R T I F I C A T E

Certificate registration number: G3.1512.063.2.A2

Certificate holder: ELSTER - EnergyICT NV/SA

Device designation: RTU3,
Hardware version Rev05, Firmware version 1.0.0Certification date: December 14th, 2015

This certificate indicates the above mentioned product successfully completed certification testing with regards to the reference specification (ITU G.9903 (02-2014) plus the changes listed in the annex to this certificate. The optional feature coherent mode of the G3-PLC protocol is also covered by this certification.

The certificate applies to certification profile Metering Cenelec A and the device was configured as a PAN-Coordinator.

Test cases have been performed as described in the test report referred to below. This certificate is granted on account of tests conducted by Laboratoire des Applications Numériques (LAN) in Tauxigny, France in November – December 2015. The results and remarks can be found in the complete test report.

Applied tests	Performed by	Document evidence
Conformance, interoperability and performance testing according to the test specification referenced by the test report	Laboratoire des Applications Numériques (LAN)	LAN15AF045


The device tested is a G3-PLC CENELEC A 3-phase combined gateway - data concentrator and router. The meter is equipped with the G3-PLC certified platform TMD50C3359 with certificate no. G3.1512.068.1.A2. The Protocol Implementation Conformance Statement in the Annex includes the PICS related to performance and is an integral part of this certificate. This certificate is valid from December 14th, 2015.

The certificate is only applicable to the product described above and permits the use of the G3-PLC™ logo as laid down in the G3-PLC logo license agreement. The certificate may only be reproduced in full.

This certificate does not imply assessment of the production. This certificate shall not be defined, or used as a guarantee covering quality of a product which includes G3-PLC. The liability of the Alliance and the test laboratory or any of her representatives is excluded for any damages or losses of the certified company.

Paris, December 14th, 2015

For the G3-PLC Alliance:


Bernard Lassus
ChairmanMadeleine Francillard
Chair Certification Program**G3-PLC**
Alliance

Annex 1: Reference Version for Certification

The reference version for this certificate is published in 'Narrowband OFDM PLC specifications for G3-PLC network, April 2015'.

The reference version for this certification is:

ITU-T G.9903 (02-2014)

- + CCTT #24-25-30: Implementation of MAC security (anti-replay) solution F1
- + CCTT #61: ADPM-Buffer behavior clarification
- + CCTT #143: AC Phase Detection v2
- + CCTT #144: Hop Limit usage during route repair v3
- + CCTT #145: Value of RCoord when the node is at adpMaxHops hops from the coordinator
- + CCTT #146: Pilot tone generation
- + CCTT #147: Link-cost computation for Path discovery v2
- + CCTT #148: Path discovery frame routing v3
- + CCTT #152: Scrambler reset
- + CCTT #154: Clarification of PANCount and PANDescriptor
- + CCTT #156: Clarification of ADPM-NETWORK-STATUS.indication
- + CCTT #157: Interleaver Equation v2
- + CCTT #158: Unicast Routing Process
- + CCTT #159: Correct the windowing function description
- + CCTT #160: Clarify 16QAM quantisation and optionality
- + CCTT #161: Correct aMaxFrameSize and aMinFrameSize for FCC/ARIB bandplans
- + CCTT #162: Interleaver co-prime number clarification v2
- + CCTT #163: CRC5 and CRC8 packing order
- + CCTT #164: Route Repair v2
- + CCTT #165: Clarification Neighbour Table v2
- + CCTT #167: HOP COUNT metric identifier v2
- + CCTT #169: Clarification on PLME_GET v4
- + CCTT #170: Clarification to Frame Counter Handling Mechanism v2
- + CCTT #172: Windowing in coherent mode
- + CCTT #173: Clarification of LOADng mechanism used to detect bidirectional links
- + CCTT #174: Avoiding duplicated MAC packets
- + CCTT #175: LOADng - subsequent RREP generation
- + CCTT #176: Link cost function of LQI v3
- + CCTT #177: Broadcast routing - filtering frames on the source
- + CCTT #178: Coexistence of G3-PLC with other PLC technologies v3
- + CCTT #179: RREP Filtering v3
- + CCTT #181: Route Repair v2

Annex 2: Protocol Implementation Conformance Statement (PICS)

Feature implementation statement

Name	Value	Description
BAND_PLAN	CENELEC A	Indicate the band-plan supported by the device.
FEATURE_PAN_COORDINATOR	TRUE	Indicate if the device is a PAN-Coordinator (true) or a normal device (false)
FEATURE_COHERENT_MODULATION	TRUE	Indicate if coherent modulation is supported
FEATURE_EAP_SERVER	TRUE	Indicate if an EAP-PASK server is implemented by the DUT. Apply only if FEATURE_PAN_COORDINATOR = true
FEATURE_DBPSK_MODULATION	TRUE	Indicate if DBPSK modulation is supported
FEATURE_ROUTING	TRUE	Indicate if the routing is implemented by the IUT
FEATURE_SECURITY	F1	Indicate the security implemented by the device. Possible values are: F1, F2.
FEATURE_ACTIVE_SCAN	TRUE	Indicate if the active scan process is done by the IUT after power-up
FEATURE_PREAMBLE_COEXISTENCE_MECHANISM	FALSE	Indicate if the preamble-based coexistence mechanism is used by the IUT.



Annex 2: Protocol Implementation Conformance Statement (PICS)

PICS related to performance (1/2)

The device tested is a G3-PLC CENELEC A 3-phase combined gateway - data concentrator and router communicating on 3 phases. Testing was performed on phase 1.

Operating voltage applied for certification testing was 230V/50Hz.

Name	Value	Unit	Description
<i>PICS related to performance are available through vendor only.</i>			

Annex 2: Protocol Implementation Conformance Statement (PICS)

PICS related to performance (2/2)

Name	Value	Unit	Description
<p>PICS related to performance are available through vendor only.</p>			

Annex 3: Copy of test report cover sheet



G3-PLC Certification Test Report

ELSTER RTU3 (4000) RTU3 (4000) FW: V1.0.0

LAN: 15AF045 2015 December 9, 2015 Page: 5/6

G3-PLC
Alliance

G3-PLC Product Certification Test Report

Vendor Name **ELSTER**
 Model Name **RTU3**
 Serial N° **679-05A852-1540**
 HW version **Rev03**
 FW version **v1.0.0**

Test Report # **TR_LAN15AF045 Ed.00**
 Date **December 9, 2015**

CONF Tests Specification **version 0.10. 01/09/2015**
 CONF Tests Suite **version 2.1. 10/2015**
 IOT Tests Specification **version 0.7. 21/04/2015**
 IOT Tests Suite **version 2.1.10/2015**
 PDRF Tests Specification **version 0.14. 30/05/2015**
 PDRF Tests Suite **version 2.1. 10/2015**

Test Tool **version 1.7**
 Tester Model **version 1.03**
 Certification Test Procedures **version 1.5 01/12/2015**

Certification Profile **A (CENELEC A)**
 Role **Combined Gateway - Data Concentrator and Router (PANC)**
 Overall Verdict **PASS**



Initiation	Date	Description of modification	Ed.
Over G3-PLC	December 9, 2015	Creation	01
Name	Realized by	Checked by	Approved by
Date	Over G3-PLC December 9, 2015	Vendor ELSTER A December 9, 2015	Henry (LAN 002) December 9, 2015
Sign			

This report is valid only if the test results (conditional data included) are given for identification only, and must not be used as a basis for any other action.

This report contains an assessment of the conformity stated, and is strictly intended for the addressee. The results in this report shall not be used for any other purpose and are intended for the product addressee. The holder is responsible for the validity of the report. It should be noted that technical progress or subsequent modifications to the specification may require the validity of this document.